

SUBMITTAL DRAWING

ากกา

9400 LINEAR SLOT DIFFUSERS


1/2", 3/4", & 1" SLOT WIDTHS WITH UP TO 10 SLOTS, IN SECTION LENGTHS OF 12" MINIMUM TO 72" MAXIMUM. FIELD BUTT FOR CONTINUOUS RUN.


EXTRUDED ALUMINUM; 6063-T5

FINISH - SA (CLEAR ANODIZE) OR W (WHITE PAINTED)

LENGTHS GREATER THAN 72" ARE FURNISHED IN MULTIPLE SECTIONS, THE NUMBER WILL BE DETERMINED BY THE FACTORY.

MAXIMUM PATTERN CONTROLLER LENGTH IS 24". PATTERN CONTROLLERS ARE FURNISHED IN MULTIPLE SECTIONS FOR A DIFFUSER LONGER THAN 24".





3/4" MARGIN - T-BAR - 672

DIMENSION	TYPE				NU	MBER C	F SLOTS	3		"D"	"0"	"W"		
		1	2	3	4	5	6	7	8	9	10	D		, vv
	1/2"	1 1/4	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	11 1/4	12 1/2	A + 7/16	A + 1/2	A + 3/4
A [3/4"	1 1/2	3	4 1/2	6	7 1/2	9	10 1/2	12	13 1/2	15	A + 7/16	A + 1/2	A + 3/4
	1"	1 3/4	3 1/2	5 1/4	7	8 3/4	10 1/2	12 1/4	14	15 3/4	17 1/2	A + 7/16	A + 1/2	A + 3/4

3/4" MARGIN - SURFACE MOUNT - 672 - HANGER BRACKET

DIMENSION	TYPE				NU	MBER C	F SLOTS	3		"D"	"0"	W A 70		
DIMENSION	ITE	1	2	3	4	5	6	7	8	9	10	"ט"	"	"W"
	1/2"	1 1/4	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	11 1/4	12 1/2	A + 3/4	A + 13/16	A + 3/4
A	3/4"	1 1/2	3	4 1/2	6	7 1/2	9	10 1/2	12	13 1/2	15	A + 3/4	A + 13/16	A + 3/4
	1"	1 3/4	3 1/2	5 1/4	7	8 3/4	10 1/2	12 1/4	14	15 3/4	17 1/2	A + 3/4	A + 13/16	A + 3/4

SIZE SCHEDULE

DWG NO.		
02HV097A	JOB NAME:	ENGINEER:
0211V037A	LOCATION:	CONTRACTOR:
DATE:	ECCATION.	CONTRACTOR.
03/26/02	ARCHITECT:	FINISH:
03/26/02	ARCHITECT:	FINISH: