

SUBMITTAL DRAWING

วกกว

9400 LINEAR SLOT DIFFUSERS


1/2", 3/4", & 1" SLOT WIDTHS WITH UP TO 10 SLOTS, IN SECTION LENGTHS OF 12" MINIMUM TO 72" MAXIMUM. FIELD BUTT FOR CONTINUOUS RUN.


EXTRUDED ALUMINUM; 6063-T5


FINISH - SA (CLEAR ANODIZE) OR W (WHITE PAINTED)

LENGTHS GREATER THAN 72" ARE FURNISHED IN MULTIPLE SECTIONS, THE NUMBER WILL BE DETERMINED BY THE FACTORY.

MAXIMUM PATTERN CONTROLLER LENGTH IS 24". PATTERN CONTROLLERS ARE FURNISHED IN MULTIPLE SECTIONS FOR A DIFFUSER LONGER THAN 24".







3/4" MARGIN - AUXILIARY FRAME 805

DIMENSION	TYPE				NU	MBER O	F SLOTS	3		"D"	"()"	"W"		
		1	2	3	4	5	6	7	8	9	10	D		"
А	1/2"	1 1/4	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	11 1/4	12 1/2	A + 13/16	A + 7/8"	A + 15/16"
	3/4"	1 1/2	3	4 1/2	6	7 1/2	9	10 1/2	12	13 1/2	15	A + 13/16	A + 7/8"	A + 15/16"
	1"	1 3/4	3 1/2	5 1/4	7	8 3/4	10 1/2	12 1/4	14	15 3/4	17 1/2	A + 13/16	A + 7/8"	A + 15/16"

1 1/8" MARGIN - AUXILIARY FRAME 806

DIMENSION	TYPE				NU	MBER C	F SLOTS	3		"""	"0"	113 A (11		
		1	2	3	4	5	6	7	8	9	10	"ט"	"C"	"W"
А	1/2"	1 1/4	2 1/2	3 3/4	5	6 1/4	7 1/2	8 3/4	10	11 1/4	12 1/2	A + 3/4	A + 13/16	A + 3/4
	3/4"	1 1/2	3	4 1/2	6	7 1/2	9	10 1/2	12	13 1/2	15	A + 3/4	A + 13/16	A + 3/4
	1"	1 3/4	3 1/2	5 1/4	7	8 3/4	10 1/2	12 1/4	14	15 3/4	17 1/2	A + 3/4	A + 13/16	A + 3/4

SIZE SCHEDULE

DWG NO.		
02HV099A	JOB NAME:	ENGINEER:
0211V033A	LOCATION:	CONTRACTOR:
DATE:	EOGATION.	CONTRACTOR.
03/26/02	ARCHITECT:	FINISH:
00,20,02		